




OWNER INSPECTIONS

1300 471 805

booking@ownerinspections.com.au

<https://www.ownerinspections.com.au/>



PRACTICAL COMPLETION INSPECTION (PCI)

Sample Property

Sample Property

Name withheld

23/07/2026



Inspector

Ibrahim Durdu

Registered Building Practitioner

1300 471 805

booking@ownerinspections.com.au

TABLE OF CONTENTS

1: + Inspection Details	11
2: + Inspection Summary	12
3: + Utilities	13
4: + House Internal	14
5: + Kitchen	20
6: + Laundry Room	23
7: + Bathrooms/Ensuites/Toilets	25
8: + Glazing	28
Standards of Practice	29

Inspection Agreement

1. This is an Agreement between you, the undersigned Client, and us, Owner Inspections.
2. If there is more than one Client, you are signing on behalf of all of you, and you represent that you are authorised to do so.
3. 'Owner Inspections' Report carries out in accordance with the guidelines of Australian Standard 4349.1 2007 (Standard) which covers the minimum requirements for the Visual Inspection of residential buildings. The purpose of the Inspection is to provide a visual inspection and provide in-writing advice only to the prospective purchaser/owner regarding the condition of the property at the date and time of Inspection.
4. The Report is NOT a certificate of compliance that the property complies with the requirements of any Act, regulation, ordinance, local law or by-law, local council or other authorities, or as a warranty or an insurance policy against problems developing with the building in the future.
5. The Report is based on the condition of the inspected property at the date and time of Inspection. While the Inspection and Report conducted and prepared with the possible care, still some access limitation and safety hazards can limit the Inspector's ability to detect all defects. These limits and safety items are defined in the standards.
6. The Report assumes that the existing use of the building will continue. If the vendor/owner wishes to change the use of the property, a permit to be acquired from the local authorities.
7. This Report does not include the identification of unauthorised building work or work not compliant with building/council regulations. The Report does not include identification of the municipality regulations and requirements as well as identification of design defects for the construction. According to the Standards, the estimate of the costs of the rectifications is not required in this Report.
8. The construction stage Inspection Report is prepared based on the opinion and assessment of the Inspector at the date and time of the Inspection on the general condition of the inspected property. The Report will not guarantee to include all defects. The Report reflects the quality of workmanship only and will not diminish the responsibility of the builder. The building company has and will have the full responsibility of the build as specified in the law and regulations. This Inspection Report is to Client as a piece of advice and is not a mandatory stage Inspection specified in the Acts and Regulations and building permit.
9. We do not perform engineering, architectural, plumbing, or any other job function requiring an occupational license in the jurisdiction where the property located. If we hold a valid occupational license, we may inform you of this, and you may hire us to perform additional functions. Any agreement for such additional services shall be in a separate writing.
10. Checking Legal matters, building contract, design, easements, local council restrictions and requirements, crossovers, title, boundaries, connections, building

envelope, planning and building permits, setbacks and zonings are out of this Inspection and Report scope of work.

11. The Report will not include defects that may only be apparent in certain weather conditions or defects that have not yet appeared due to prolonged periods of wet or dry weather or other reasons.

12. An inspector shall only inspect areas where safe and unobstructed access provided. Reasonable access is defined in AS4349.1-2007 and this Agreement. Reasonable access does not include removing stored material/goods, nails, screws, cutting or making access hole, and moving furniture.

13. We will not test for the presence of radon, a harmful gas, mould, presence of asbestos, soil contamination, or other environmental hazards or violations.

14. The Report does not identify the presence of pests, or any damage caused by pests (e.g. termites, borers, etc.) unless the Client added to the requested service.

15. The Inspection is not intended to include rigorous assessment of all building elements in a property. Any maintenance and general advice items are a helpful guide only. The Report does not necessarily include all maintenance items.

16. If you request a re-Inspection, the re-Inspection is subject to the terms of this Agreement and re-Inspection fee.

17. The Report will be based on the Inspector's assessment on major defects and safety hazards evident and visually visible on the date and time of the Inspection. The Report will also provide a general assessment of the property and collectively comment on minor defects which would form a regular part of property maintenance.

18. Limitation on Liability and Damages: We are not liable for any cost of repair or replacement of unreported defects, either current or arising in the future. In all cases, our liability is limited to liquidated damages in an amount not greater than 1.5 times the fee you paid us. You waive any claim for consequential, exemplary, special or incidental damages or for the loss of the use of the home/building. You acknowledge that these liquidated damages are not a penalty, but that we intend it to: (i) reflect the fact that actual damages may be difficult or impractical to ascertain; (ii) allocate risk between us; and (iii) enable us to perform the Inspection for the agreed-upon fee. If you wish to eliminate this liquidated damage provision, we are willing to perform the Inspection for an additional fee of \$2,000 payable in advance upon your request.

19. Our Inspection and Report are for your use only. You give us permission to discuss our observations with real estate agents, owners, builders, or other interested parties. You will be the sole owner of the Report and all rights to it. We are not responsible for the use or misinterpretation by third parties, and third parties who rely on it in any way do so at their own risk and release us (including employees and business entities) from any liability whatsoever. You are not allowed to send/show our Report and/or a quotation to our market competitors. If Owner Inspections realise that our competitor has/saw our Report belonging to you and your property, we have the right to take legal action to retrieve damages. If you or any person acting on your behalf provide the Report to a third party who then sues you and/or us, you release us from any liability and agree to pay our costs and legal fees in defending any action naming us. Our Inspection and Report are in no way a guarantee or warranty, express or implied, regarding the future

use, operability, habitability or suitability of the home/building or its components. We disclaim all warranties, express or implied, to the fullest extent allowed by law.

20. You agree that the exclusive venue for any litigation arising out of this Agreement shall be in Australia, where we have our principal place of business. If you fail to prove any claim against us, you agree to pay all our legal costs, expenses and attorneys' fees incurred in defending that claim.

21. If a court declares any provision of this Agreement invalid, the remaining provisions remain in effect. This Agreement represents our entire Agreement; there are no terms other than those set forth herein. All prior discussions are merged into this Agreement. No statement or promise by us shall be binding unless reduced to writing and signed by one of our authorised officers. Any modification of this Agreement must be in writing and signed by you and by one of our authorised officers. This Agreement shall be binding upon and enforceable by the parties and their heirs, executors, administrators, successors and assignees. You will have no cause of action against us after one year from the date of the Inspection.

22. If a court finds any term of this Agreement ambiguous or requiring judicial interpretation, the court shall not construe that term against us because of the rule that any ambiguity in a document is construed against the party drafting it. You had the opportunity to consult qualified legal advice before accepting this Agreement.

23. You may not assign this Agreement.

24. BY BOOKING THE INSPECTIONS, YOU CONFIRM THAT YOU HAVE CAREFULLY READ THIS AGREEMENT. YOU AGREE TO IT AND ACKNOWLEDGE RECEIVING A COPY OF IT.

Purpose of Inspection

The purpose of the Inspection is to provide advice to a prospective purchaser or other interested parties regarding the condition of the property at the time of Inspection.

Conditions of Inspection

An Inspection Report may be conditional on Prevailing weather conditions or recent occupancy and use of services that might affect observations; Information provided by the Client or the agents of the Client; Deliberate concealment of defects; Any other relevant factor limiting the Inspection.

Scope of Inspection

The Inspection shall comprise visual assessment of the property to identify major defects and to form an opinion regarding the general condition of the property at the time of Inspection. Where the Client or other interested party requires only assessment of the structure of the property, the scope of the Inspection shall be limited to that described in Appendix C, AS4349.1-2007. An estimate of the cost of rectification of defects is not required in an Inspection report in accordance with this Standard.

Inspection Records

The Inspector shall record the following information prior to, or during the course of, the Inspection: Identity of the Inspector undertaking the Inspection; Identity of the Client; The address of the property inspected; Date of Inspection; Weather conditions at the

time of the Inspection; Limitations of Inspection with respect to the accessible area; Observation of defects.

Areas for Inspection

The Client shall arrange right of entry, facilitate physical access to the property and supply necessary information to enable the Inspector to undertake the Inspection and prepare a report. The Inspector is not responsible for arranging access to property or parts of the property. Areas where reasonable entry is denied to the Inspector, or where reasonable access is not available, are excluded and do not form part of, the Inspection.

The Inspector shall inspect accessible parts of the building and appurtenances, together with the relevant feature of the property within 30 m of the building and within the boundaries of the site, or as otherwise agreed in the Inspection Agreement. In this context, relevant features include car accommodation, detached laundry, ablution facilities and garden sheds, retaining walls more than 700 mm high, paths and driveways, steps, fencing, earth embankments, surface water drainage and stormwater run-off.

The following areas shall be inspected where applicable: The interior of the building; The roof space; The exterior of the building; The sub-floor space; The roof exterior; The property within 30 m of the building subject to Inspection.

Significant items to be reported are as follows:

- (a) Major defects.
- (b) A general impression regarding the extent of minor defects, for example, significantly deteriorating exterior paint.
- (c) Any major defect that is an urgent and serious safety hazard, for example, unsafe balustrades or imminent collapse of a structural member.

Items to be inspected where applicable:

Interior: Ceilings, Walls, Timber floors, Concrete floors, Timber or steel frames and structure, Timber windows, Metal/Aluminium framed windows, Doors and Frames, Kitchen: Benchtop, Cupboards, Sink/Taps, Tiles, Bathroom/WC/Ensuite: Cistern and pan, Bidet, Taps, Tiles, Bath, Shower, Vanity, Basins, Ventilation, Mirror; Laundry: Taps, Tubs/Cabinet, Tiles, Ventilation; stairs: Stringer, Handrail/Balusters, Treads and risers.

Exterior: Walls, Timber or steel frames and structure, Stairs, Balconies, Verandas, patios, decks, suspended concrete floors, balustrades, Roof, Skylight, Valleys, Guttering, Downpipes, Eaves, Fascia and barges.

Roof Space: Roof covering, Roof framing, Sarking, Party walls, Insulation.

Subfloor Space: Timber Floor, Suspended concrete floors.

The site: Car accommodation, detached laundry, ablution facilities and garden sheds, Retaining walls, Paths and driveways, Steps, Fencing, Surface-water.

Exclusion of items from Inspection:

Footings below ground.

The operation of fireplaces, solid fuel heaters, chimneys and flues.

Electrical appliances including dishwashers, incinerators, ovens, ducted vacuum Systems, Alarm and Intercom systems, air-conditioning.

Swimming pools and associated filtration and similar equipment.

Concealed damp-proof course, plumbing, gas fitting and fixtures.

Concealed tie-downs and bracing, framing-timbers or any areas concealed by wall linings/sidings.

Health hazards (e.g., allergies, soil toxicity, lead content, radon, presence of asbestos or urea-formaldehyde).

Soil conditions, control joints.

Sustainable development provisions, Environmental matters (e.g., BASIX, water tanks, NCC Environmental Provisions), Energy and lighting efficiency, Landscaping.

Rubbish, Stored items, furniture and accessories.

Safe and reasonable access

The extent of accessible areas shall be determined by the Inspector at the time of Inspection,

based on the conditions encountered at the time of Inspection. The Inspector shall also determine whether sufficient space is available to allow safe access. The Inspection shall include only accessible areas and areas that are within the Inspector's line of sight and close enough to enable reasonable appraisal. Reasonable access shall be determined as below:

Roof interior: minimum 400mm x 500mm access hole, 600mm x 600mm crawl space, accessible from a 3.6m ladder.

Roof exterior: Accessible from a 3.6m ladder placed on the ground.

Sub Floor Area: 400mm x 500mm access hole; 400mm x 500mm crawl space.

Reasonable access does not include the cutting of access holes or the removal of screws and bolts or any other fastenings or sealants to access covers.

Subfloor areas sprayed with chemicals are not to be inspected unless it is safe to do so. Areas, where reasonable entry is denied to the Inspector or where reasonable access is not available, are excluded from and do not form part of the Inspection.

Access Limitation:

The Inspector will conduct a non-invasive visual Inspection which will be limited to those accessible areas and sections of the property to which Safe and Reasonable Access is both available and permitted on the date and time of the Inspection. Areas where reasonable entry is denied to the Inspector, or where safe and reasonable access is not available, are excluded from and do not form part of, the Inspection. Those areas may be the subject of an additional Inspection upon request following the provision or reasonable entry and access.

The Inspection excludes the inside of walls, between floors, inside skillion roofing, inside the eaves, behind stored goods in cupboards, and other areas that are concealed or

obstructed. The Inspector will not dig, gouge, force or perform any other invasive procedures.

Examples of access limitations:

Legal right of entry, locked doors/windows, security systems, pets, furniture or other Obstructions, Height, narrow boundary clearances, thick vegetation, small roof or crawl space, adverse weather conditions.

The Report shall identify any area or item within the scope of the Inspection that was not inspected and the factor that prevented Inspection.

Acceptance criteria:

The building shall be compared with a building that was constructed in accordance with the generally accepted practice at the time of construction and which has been maintained such that there has been no significant loss of strength and serviceability.

Definitions

Access hole (cover): An opening in flooring or ceiling or other parts of a structure (such as service hatch, removable panel) to allow for entry to carry out an Inspection, maintenance or repair.

Accessible area: An area of the site where sufficient, safe and reasonable access is available to allow Inspection within the scope of the Inspection.

Building element: Portion of a building that, by itself or in combination with other such parts, fulfils a characteristic function.

Client: The person or other entity for whom the Inspection is being carried out.

Defect: Fault or deviation from the intended condition of a material, assembly, or component.

Inspection: Close and careful scrutiny of a building carried out without dismantling, in order to arrive at a reliable conclusion as to the condition of the building.

Inspector: Person who is responsible for carrying out the Inspection.

Limitation: Any factor that prevents full or proper Inspection of the building.

Structural defect: Fault or deviation from the intended structural performance of a building element.

Structural element: Physically distinguishable part of a structure; for example, wall, columns, beam, connection.

Subfloor space: Space between the underside of a suspended floor and the ground.

Roof space: Space between the roof covering and the ceiling immediately below the roof covering.

Site: Allotment of land on which a building stands or is to be erected.

Defect Categories:

Visually Fine (F): Item inspected and is visually fine.

General Advice (G): A general advice item is neither defect nor fine. It is only a recommendation/advice/description by Inspector.

Defect (D): Fault or deviation from the intended condition of a material, assembly, or component. Repair is recommended on Defect items.

Major Defect (M): A defect which can cause further severe damage (structural or non-structural) to the property or make it unsafe. The rectification must carry out ASAP to avoid damages/injuries.

Unable to Inspect (U): An area where the Inspector could not inspect at the time of Inspection due to one or more safe/reasonable access limitations.

Not Applicable (N): An item that is not applicable to the area of the Inspection.

Please note: This report is ***not tribunal compliant and can not be used for any legal proceedings***. If you need a report to pursue to tribunal or court, please get in touch with our office to book an expert witness inspection, and one of our experts will attend the site and provide a Tribunal-compliant inspection report.

NEED RE-INSPECTION?

Once your builder informs you that the defects are rectified, you can book a reinspection. During the re-inspection, our inspector attends the site and checks if all defects have been rectified. Both resolved and unresolved defects will be documented and the full report will be sent to you to help you get your builder to fix all defects before the defects are covered, and construction goes to the next stage.

Simply you can book this service online [HERE](#).



GENERAL
ADVICE/MAINTENANCE
ITEMS



DEFECTS

- ⊖ 2.1.1 + Inspection Summary - + Inspection Summary: Overall condition
- ⊖ 4.1.1 + House Internal - + General Painting Defects: Kitchen
- ⊖ 4.1.2 + House Internal - + General Painting Defects: Laundry
- ⊖ 4.1.3 + House Internal - + General Painting Defects: Cupboard study
- ⊖ 4.2.1 + House Internal - + General Cracks: Kitchen
- ⊖ 4.4.1 + House Internal - + General Tiling: + Grouting/joints defective
- 🔧 4.5.1 + House Internal - + General Cleaning: + General Cleaning required
- ⊖ 4.6.1 + House Internal - + Doors (Internal): Cabinet damaged
- ⊖ 4.7.1 + House Internal - + Ceiling/Wall plaster: + Poor workmanship in joints setting
- 🔧 4.9.1 + House Internal - + Windows: + Fly Screen Not installed
- ⊖ 4.13.1 + House Internal - + Lights/switches/downlights: Painted
- ⊖ 5.1.1 + Kitchen - + Benchtops: + Cleaning required
- ⊖ 5.5.1 + Kitchen - + Cabinetry: + Screw Caps
- ⊖ 5.5.2 + Kitchen - + Cabinetry: Kickboard
- 🔧 5.8.1 + Kitchen - General views : General
- ⊖ 6.2.1 + Laundry Room - + Mixer/Taps/Plumbing: + Coverplate(s) not installed
- ⊖ 6.4.1 + Laundry Room - + Cabinetry: + Inconsistent Gaps - Adjustment Required
- ⊖ 6.4.2 + Laundry Room - + Cabinetry: Cover
- ⊖ 7.2.1 + Bathrooms/Ensuites/Toilets - + Plumbing/Mixer/Taps: Leaking from handle
- ⊖ 7.11.1 + Bathrooms/Ensuites/Toilets - Sealants: Inadequate sealant
- ⊖ 7.11.2 + Bathrooms/Ensuites/Toilets - Sealants: Inadequate sealant 2
- 🔧 7.13.1 + Bathrooms/Ensuites/Toilets - General views: General

1: + INSPECTION DETAILS

		F	G	D	M	U	N
1.1	+ General						
1.2	+ Limitations						

F = Visually Fine

G = General Advice

D = Defect

M = Major Defect

U = Unable to Inspect

N = Not Applicable

Information

+ General: In Attendance

Client, Selling Agent, Vendor

+ General: Weather Conditions

Clear

+ General: Bedrooms

1

+ General: Bathrooms/Ensuites

1

+ General: Type Of Building

Apartment

+ General: How Many Levels?

Multi-Storey

+ General: Car Park

Other

+ General: External Building Material

Other

+ General: Piers

Not Applicable

+ General: Building Age

New Build

+ General: Flooring

Timber, Tiles

+ General: Windows

Aluminium

+ General: Roof

Unable To Determine

Limitations

+ General

REASONABLE ACCESS TO THE PROPERTY WAS RESTRICTED BY:

Height

+ Limitations

REASONABLE ACCESS TO THE PROPERTY WAS RESTRICTED BY:

Height

2: + INSPECTION SUMMARY

		F	G	D	M	U	N
2.1	+ Inspection Summary						

F = Visually Fine G = General Advice D = Defect M = Major Defect U = Unable to Inspect N = Not Applicable

Information

+ Inspection Summary: Well presented
90
Property has presented well with very minor defects

Observations

2.1.1 + Inspection Summary

OVERALL CONDITION

-

Defects

Overall condition is of a good condition with items that will need to be completed prior to handover.

3: + UTILITIES

		F	G	D	M	U	N
3.1	+ Utilities Connection						

F = Visually Fine G = General Advice D = Defect M = Major Defect U = Unable to Inspect N = Not Applicable

Information

+ Utilities Connection: Recycled Water Not tested	+ Utilities Connection: Gas Not tested	+ Utilities Connection: Smoke Alarms Smoke detectors to be tested by electrician and certificate to be provided to client.
+ Utilities Connection: ELECTRICITY Connected	+ Utilities Connection: Main Water Connected	+ Utilities Connection: Sewer Connected
+ Utilities Connection: Stormwater system Connected		

4: + HOUSE INTERNAL

		F	G	D	M	U	N
4.1	+ General Painting Defects			X			
4.2	+ General Cracks			X			
4.3	+ General Nails popping		X				
4.4	+ General Tiling			X			
4.5	+ General Cleaning		X				
4.6	+ Doors (Internal)			X			
4.7	+ Ceiling/Wall plaster			X			
4.8	+ Skirtings / Architraves		X				
4.9	+ Windows		X				
4.10	+ Flooring - Timber		X				
4.11	+ Flooring - Carpet						X
4.12	+ H/C vents/grilles/outlets		X				
4.13	+ Lights/switches/downlights			X			
4.14	+ Smoke Detectors		X				

F = Visually Fine

G = General Advice

D = Defect

M = Major Defect

U = Unable to Inspect

N = Not Applicable

Information

+ Smoke Detectors: + Smoke detectors testing

All smoke detectors must be tested by a qualified electrician.

Observations

4.1.1 + General Painting Defects
KITCHEN

 Defects



4.1.2 + General Painting Defects
LAUNDRY

 Defects



4.1.3 + General Painting Defects
CUPBOARD STUDY

 Defects



4.2.1 + General Cracks
KITCHEN

 Defects



4.4.1 + General Tiling



Defects

+ GROUTING/JOINTS DEFECTIVE

Tile grouting and/or joint finishing found to be of poor quality in one or more areas. Adequate rectification is required.

11.06 Grouting and joints

Grouting is defective if it is not carried out in accordance with the requirements of Clause 5.7 of AS 3958.1.

Joints are defective if they are not, as far as is practicable, of consistent width and can be seen from a normal viewing position.

Finished grout is defective if it is not uniform in colour, smooth, without voids, pinholes or low spots.

- a) The top surface of the grout may be tooled to provide a contoured depression of no deeper than 1 mm for up to 6 mm wide joint and up to 2 mm for a 6-10 mm wide joint (clause 5.7(e) of AS 3958.1).
- b) Joint widths for floor tiles should not exceed 3 mm for pressed tiles and 6 mm for extruded tiles (clause 4.6(c)(i) of AS 3958.1).
- c) Joint widths for wall tiles should not exceed 1.5 mm for pressed tiles and 6 mm for extruded tiles (clause 5.4.6(c)(ii) of AS 3958.1).
- d) Joint alignment should be consistent throughout the installation within a tolerance of 4 mm in 2 m⁸ (clause 5.4.6(d) of AS 3958.1).

Grout is defective if it becomes loose within 24 months of handover.



4.5.1 + General Cleaning

+ GENERAL CLEANING REQUIRED

General Advice/Maintenance Items

General final cleaning throughout the house required prior to the handover.

18.08 Cleaning

Owners are entitled to expect that the building site and works are clean and tidy on completion. Where handover is delayed for any reason the owner must expect that dust may have settled on interior exposed surfaces.

Building sites are defective if they are not clear of building debris.

Building works are defective where windows are not clean, floors are not swept, mopped or vacuumed as appropriate, tiles, sinks, basins, troughs, baths, etc. are not cleaned, and shelving, drawers and cupboards ready for use.

4.6.1 + Doors (Internal)

CABINET DAMAGED

Defects

Built-in wardrobe cabinets are damaged. Builder to repair or replace all damaged cabinet components (doors, panels, shelves and hardware) so wardrobes present in as-new condition and operate correctly, in accordance with the contract and standard trade finish expectations



4.7.1 + Ceiling/Wall plaster

+ POOR WORKMANSHIP IN JOINTS SETTING
 Defects

One or more ceiling joint settings noted with poor workmanship quality. Repair required.

9.13 Level of finish for plasterboard

Unless documented otherwise, a plasterboard finish is defective if Level 4 finish (as defined below) is not provided.

Level 4 finish³

A Level 4 finish shall be the default level for gypsum lining, unless specified otherwise.

Flat or low sheen paints shall be used for this Level 4.

All joints and interior angles shall have tape embedded in jointing cement/jointing compound and a minimum of two separate coats of jointing cement/jointing compound applied over all joints, angles, fastener heads and accessories.

All jointing compound shall be finished evenly and be free of tool marks and ridges in preparation for decoration.

Notes:

1. In critical lighting conditions, surface imperfections may still be apparent in a Level 4 surface finish.
2. Where gloss, semi-gloss and deep tone paints are used, surface imperfections will be more evident.



4.9.1 + Windows

+ FLY SCREEN NOT INSTALLED

General Advice/Maintenance Items

One or more fly screens were not installed at the time of inspection. Builder to check the contract/variations if the fly screen is included.

fly screens are mandatory in Bushfire affected (BAL) areaa.

4.13.1 + Lights/switches/downlights

PAINTED**BEDROOM**
 Defects

Light switch toggle has been painted over. Builder to replace the affected switch mechanism and cover plate so that toggles operate freely and switchgear is clean and undamaged, in accordance with good electrical installation practice



5: + KITCHEN

		F	G	D	M	U	N
5.1	+ Benchtops			X			
5.2	+ Plumbing/Mixer/Taps	X					
5.3	+ Sink	X					
5.4	+ Splashbacks	X					
5.5	+ Cabinetry			X			
5.6	+ Oven/Stove/Rangehood		X				
5.7	Fir cap to fridge space tap		X				
5.8	General views		X				

F = Visually Fine

G = General Advice

D = Defect

M = Major Defect

U = Unable to Inspect

N = Not Applicable

Observations

5.1.1 + Benchtops

+ **CLEANING REQUIRED**

Defects



5.5.1 + Cabinetry

+ SCREW CAPS

All the screws must be covered with cover buttons.

AS 4386:2018:

Before handing over the completed assembly, the following shall be carried out:

- (a) Clean all components of dust and debris.
- (b) Test the doors, drawers and hardware for operation and check that alignments match specifications.
- (c) Check for rough edges and sand, or smooth, as necessary.

(d) Cap or conceal all visible screwheads.

(e) Fill gap between wall and panel with a paintable gap filler, where cabinets, infill panels, refrigerator panels, worktops, and any other finished panels butt to walls.

For more information, please refer to Australian Standards @ <https://www.standards.org.au/>



Defects



5.5.2 + Cabinetry

KICKBOARD

Kickboard is missing under the integrated dishwasher. Builder to install a matching, removable kickboard/plinth panel so the dishwasher base aligns with adjacent cabinet kickers and the toe space is consistently enclosed, in accordance with the kitchen joinery design and appliance installation requirements.



Defects



5.8.1 General views

GENERAL

General Advice/Maintenance Items



6: + LAUNDRY ROOM

		F	G	D	M	U	N
6.1	+ Splashback	X					
6.2	+ Mixer/Taps/Plumbing			X			
6.3	+ Sink/Trough	X					
6.4	+ Cabinetry			X			
6.5	+ Ventilation		X				
6.6	+ Exhaust Fan		X				

F = Visually Fine

G = General Advice

D = Defect

M = Major Defect

U = Unable to Inspect

N = Not Applicable

Observations

6.2.1 + Mixer/Taps/Plumbing

+ COVERPLATE(S) NOT INSTALLED

Coverplate(s) where plumbing pipes penetrate through cabinetry was not installed. The coverplates are mandatory to seal the cabinets against pest entering the building.



Defects



6.4.1 + Cabinetry

+ INCONSISTENT GAPS - ADJUSTMENT REQUIRED Defects

Inconsistent gaps noted in cabinets corners and or doors. Adjustment required.

GUIDE TO STANDARDS AND TOLERANCES 1.04

Cabinet door and drawer fronts are defective if they are not aligned, or do not have consistent gaps between them at handover, and can be seen from a normal viewing position.



6.4.2 + Cabinetry

COVER Defects

Cabinet penetrations and wall penetrations within the vanity are to be properly covered and sealed. All visible service penetrations (pipes, cables, fixings) must be finished with suitable cover plates or panels and sealed where required, in accordance with wet-area waterproofing provisions (NCC Part 10.2 and AS 3740) and good trade practice



7: + BATHROOMS/ENSUITES/TOILETS

		F	G	D	M	U	N
7.1	+ Splashback	X					
7.2	+ Plumbing/Mixer/Taps			X			
7.3	+ Shower	X					
7.4	+ Shower screen	X					
7.5	+ Vanity/Cabinetry	X					
7.6	+ Basin	X					
7.7	+ Exhaust Fan	X					
7.8	+ Bath	X					
7.9	+ Toilet	X					
7.10	+ Ventilation	X					
7.11	Sealants			X			
7.12	+ Lights/switches/downlights	X					
7.13	General views		X				

F = Visually Fine

G = General Advice

D = Defect

M = Major Defect

U = Unable to Inspect

N = Not Applicable

Information

+ Shower: Note to client:

Important Notes: The shower have been checked against the visual leakage, however, the shower leakage usually appears after long term use. We recommend maintaining the sealing and prevent them from any damages as one of the main water leak reasons.

Observations

7.2.1 + Plumbing/Mixer/Taps

LEAKING FROM HANDLE



Defects



7.11.1 Sealants

INADEQUATE SEALANT

Sealant is inadequate in one or more areas, and requires repair to prevent water escape.



7.11.2 Sealants

INADEQUATE SEALANT 2

Sealant is inadequate in one or more areas, and requires repair to prevent water escape.



7.13.1 General views

GENERAL

General Advice/Maintenance Items



8: + GLAZING

		F	G	D	M	U	N
8.1	+ Mirrors, windows and doors glassses	X					

F = Visually FineG = General AdviceD = DefectM = Major DefectU = Unable to InspectN = Not Applicable

STANDARDS OF PRACTICE
